

# HUMBOLDT STATE UNIVERSITY

February 10, 2021

To All Prospective Proposers

SUBJECT: RFP #PW20-JOC, Job Order Contract

## **Addendum #2**

The following changes, omissions and/or additions to the Bidding Documents shall apply to proposals made for and to the execution of the various parts of the work affected thereby and all other conditions shall remain the same. In case of conflict between Bidding Documents and this Addendum, this Addendum shall govern.

1. The following is provided in answer to a question posed by a potential bidder:

Question: Is there a pre-approval process for alternate generator manufacturers? Also, the specification looks like a proprietary Cummins spec due to the 50 Mile service location requirement. Is there any latitude on this?

Answer: The process for alternates or substitutions is outlined in Exhibit C, Contract General Conditions for Design-Bid-Build Major Projects Section 5.04, Shop Drawings, Samples, Alternatives or Equals, Substitutions. the requirement in service area will remain unchanged. Proposers may partner with local service to meet these requirements if available.

**-END OF ADDENDUM-**

Contracts & Procurement

Addie Dunaway  
Procurement Specialist