

SOLAR PHOTOVOLTAIC RFP PW22-3 COVER SHEET

CAL POLY HUMBOLDT

University Contact Information for Solicitation	Addie Dunaway Procurement Specialist addie.dunaway@humboldt.edu
RFP Issue Date	30-Nov-22
Technical Proposal Due	1/31/2023 @ 3 PM
Cost Proposal Due	1/31/2023 @ 3 PM
SECTION I – OVERVIEW	
Interconnection Fees Treatment	By Owner
Basis of Award	By Campus
Selection and award schedule dates	December 15, 2022 @ 10 AM
Mandatory Virtual Prebid Meeting	
Zoom Link	https://humboldtstate.zoom.us/j/89100799675?pwd=MTA0Y21COTdramxJSiY5N0dlazMydz09
Zoom Meeting ID	891 0079 9675
Zoom Meeting Passcode	135965
Job Walk	January, 5 2023 @ 10 AM
Deadline for RFP Questions	January, 12 2023 5 PM
Issuance of Addenda – if necessary	January 18, 2023
Notice of Intent to Award	February 16, 2023
Contract Award	March 17, 2023
Construction schedule dates	
Start of Construction	May 22, 2024
Parking lot Construction Complete	August 18, 2024
Interconnection and Project Completion	December 31, 2024
SECTION IV – SCOPE OF SERVICES	
Campus Preferred Term	20
Local Electric Utility	PG&E
	Assessed by Liquidated Damages
Construction Delays	\$1,000 per day
CEQA Status	Campus to complete CEQA
Net Energy Metering (NEM) Availability	No Export
SECTION V – TECHNICAL PROPOSAL REQUIREMENTS AND EVALUATION	
Campus Standards, Guidelines and policies	
Campus Electrical Conduit Standards (Rigid Vs. EMT)	Rigid
Campus Contractor Safety Handbook	https://risksafety.humboldt.edu/environmental-health-safety-0
Campus Design Criteria	N/A
Campus Risk Management and Environmental Health & Safety Policies	https://risksafety.humboldt.edu/environmental-health-safety-0
Campus Meters Standards	https://link.humboldt.edu/Zpg
Lighting Standards	Open parking lots must provide an average of five (5) foot candles and a minimum of one (1) foot
Carport Structural Finishes	Structural members hot-dipped galvanized
Required Conductor Type	Copper
Tree Trimming & Removal	Campus to trim and/or replace trees
Penalty Rate for Non-Operation	Assessed through performance guarantee (Rider C)
Voltage at High and low side of campus main meter	12,000 V - 12,000V
Incentives	Solar Yes
University Hurdle Rate	Solar (Cents/kwh) 16
Lowest Annual Peak Demand (Daytime)	1 MW
Maximum kWh/kW Willing to Purchase	3,900,000 kWh/yr, 3,000 kW
Attach 15-Mins Interval Data	https://link.humboldt.edu/ZW7
Attach Fire Vehicle Access Standards	13'6" height, 20' aisle width
Attach Electrical Single Line Diagram	https://link.humboldt.edu/ZW8
Attach campus as-built drawings and data	available in contract